

**EXHIBIT H**

BUILDING 2700 ACM ASSESSMENT

**PLEASE SEE NJEDA WEBSITE FOR THIS EXHIBIT AS POSTED  
SEPARATELY**

## *Sample Summary by Building for Positive Results*

**Building Number**     2700

**Floor**     1st Floor

*SampleID*     *V1B107-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 1	10%	RACM	Good	532 square feet	F27000 4	4/5/2001

*SampleID*     *V1B10-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 6	10%	RACM	Good	140 square feet	F27000 9	4/5/2001

*SampleID*     *V1B133-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 2	10%	RACM	Good	1050 square feet	F27000 5	4/5/2001

*SampleID*     *V1B136-TSI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	1st floor section 2	10%	RACM	Good	2 Linear Feet	F27000 5	4/5/2001

*SampleID*     *V1B138-DI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Duct Insulation	1st floor section 2 rm 1B38	2 %	RACM	Good	1500 square feet	F27000 5	4/5/2001
-----------------	-----------------------------	-----	------	------	------------------	-------------	----------

**SampleID**      *V1B144-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 2 locate between I 17-II 8	10%	RACM	Good	6020 square feet	F27000 5	4/5/2001

**SampleID**      *V1B307-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 4 located III 4	10%	RACM	Good	272 square feet	F27000 7	4/5/2001

**SampleID**      *V1B313-TSI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	1st floor section 4 located III 6-III 7	10%	RACM	Good	3 Linear Feet	F27000 7	4/5/2001

**SampleID**      *V1B318-TSI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	1st floor section 4 located between III 7-III 8	10%	RACM	Good	6 Linear Feet	F27000 7	4/5/2001

**SampleID**      *V1B325-TSI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Panel Insulation	1st floor section 5	10%	RACM	Good	80 Linear Feet	F27000 8	4/5/2001

**SampleID**      *V1B403-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 6	10%	RACM	Good	1200 square feet	F27000 9	4/5/2001

**SampleID**      *V1B415-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 7	10%	RACM	Good	3211 square feet	F27001 0	4/5/2001

**SampleID**      *V1FLSEC1-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 1	10%	RACM	Good	8186 square feet	F27000 4	4/5/2001

**SampleID**      *V1FLSEC3-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 3 located II 8-II 19	10%	RACM	Good	13375 square feet	F27000 4	4/5/2001

**SampleID**      *V1FLSEC4-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	1st floor section 4 located II 19-III 8	10%	RACM	Good	6500 square feet	F27000 7	4/5/2001

**SampleID**      *V1FLSEC5-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Floor Tile	1st floor section 5	10%	RACM	Good	415 square feet	F27000 8	4/5/2001
------------	---------------------	-----	------	------	-----------------	-------------	----------

**SampleID**      *VIFLSEC5-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 5 located III 15-III 16	10%	RACM	Good	1500 square feet	F27000 8	4/5/2001

**SampleID**      *VIFLSEC6-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor section 6	10%	RACM	Good	512 square feet	F27000 9	4/5/2001

**SampleID**      *VIFLSW6-TSI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	1st floor stairwell 6	10%	RACM	Good	1 Linear Feet	F27000 9	4/5/2001

**SampleID**      *VCS-118-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Insulation	1st floor section 2	10%	RACM	Good	6 Linear Feet	F27000 5	4/5/2001

**SampleID**      *VINC-TSI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	1st floor section 5 located V2	10%	RACM	Good	5 Linear Feet	F27000 8	4/5/2001

**SampleID** VSW-001

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	ALL STAIRS	10%	RACM	Good	1300 square feet	F27006 7	4/5/2001

**Floor** 1st Floor Crawlspace

**SampleID** ICS-TSI-001

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 1 CS SECTION 2	40%	RACM	Good	10 Surface Area	F27001 2	4/28/2001

**SampleID** ICS-TSI-002

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 1 CS. From stairwell #3. 1ST FLOOR CAT WALK SECTION 2	40%	RACM	Good	10 Linear Feet	F27001 2	4/28/2001

**SampleID** ICS-TSI-003

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 1 CS. from stairwell#3. 1ST FLOOR CAT WALK SECTION 2	40%	RACM	Good	10 Linear Feet	F27001 2	4/28/2001

**SampleID** VICSI18-DI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Mastic	1st floor section 2	2 %	RACM	Good	800 Linear Feet	F27001 2	4/5/2001

**SampleID** VCS-i11-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	1st floor cat walk SECTION 1	10%	RACM	Good	75 Linear Feet	F27001 1	3/15/2001

**SampleID** VCS-I14-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	1st floor cat walk section 2. Located B/ I 15	10%	RACM	Good	4 Linear Feet	F27001 2	3/15/2001

**SampleID** VCSII5-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	1st floor section 2	10%	RACM	Good	4 Linear Feet	F27001 2	4/28/2001

**SampleID** VCS-I2-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	1st floor cat walk section 1, B/I2	10%	RACM	Damaged	8 Linear Feet	F27001 1	3/15/2001

**SampleID** VCS-I4-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	1st floor cat walk section 1	10%	RACM	Good	3 Linear Feet	F27001 1	3/15/2001

**SampleID** VCS-III1-TSI-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Debris	1st floor cat walk section 3. Location: B-C/ II 11- II 10	10%	RACM	Good	50 Linear Feet	F27001 3	3/15/2001
--------	---	-----	------	------	----------------	-------------	-----------

**SampleID** *VCS-III4-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Insulation	1st floor cat walk section 3. Location: B-C/ II 14- II 13	10%	RACM	Damaged	27 Linear Feet	F27001 3	3/15/2001

**SampleID** *VCS-III-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	1st floor cat walk section 2. By hatchway to stairwell #3. B-C/II 1-1 18	10%	RACM	Good	4 Linear Feet	F27001 2	3/15/2001

**SampleID** *VCS-II2-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	1st floor cat walk section 2	10%	RACM	Damaged	2 Linear Feet	F27001 2	3/15/2001

**SampleID** *VCS-II7-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	1st floor section2. A-B/II 8-II 7	10%	RACM	Significantly Damaged	4 Linear Feet	F27001 2	3/15/2001

**SampleID** *VCS-III10-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Fitting	1st floor cat walk section 5. Location D/ III 10	10%	RACM	Good	5 square feet	F27001 5	3/15/2001

**SampleID**      *VCS-III12-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	1st floor cat walk section 5. Location: D/ III 12- III 13	10%	RACM	Good	5 Linear Feet	F27001 5	3/15/2001

**SampleID**      *VCS-III3-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	1st floor cat walk section 4. Located: D-C/ III 3- III 4	10%	RACM	Good	2 square feet	F27001 4	3/15/2001

**SampleID**      *VCS-III6-DI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Duct Insulation	1st floor Cat walk section 4	3 %	RACM	Good	2000 square feet	F27001 4	4/5/2001

**SampleID**      *VCS-IV1-TSI-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Insulation	1st floor cat walk section 5	10%	RACM	Good	100 Linear Feet	F27001 5	4/5/2001

**Floor**    2nd Floor

**SampleID**      *2C109-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 1	10%	RACM	Good	845 square feet	F27002 5	4/5/2001

**Floor** 2nd Floor

*SampleID* 2C109-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 1	10%	RACM	Good	845 square feet	F27002 5	4/5/2001

**SampleID** 2C129-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 2	10%	RACM	Good	425 square feet	F27002 6	4/5/2001

**SampleID** 2C205-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 3	10%	RACM	Good	295 square feet	F27002 7	4/5/2001

**SampleID** 2C215-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 3	10%	RACM	Good	810 square feet	F27002 7	4/5/2001

**SampleID** 2C415-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 7	10%	RACM	Good	232 square feet	F27003 1	4/5/2001

**SampleID** V2C211-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 3	1-	RACM	Good	376 square feet	F27002 7	4/5/2001

**SampleID** V2C307-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Transite	2nd floor section 4	10%	RACM	Good	1120 square feet	F27002 8	4/5/2001
----------	---------------------	-----	------	------	------------------	-------------	----------

**SampleID** V2C311-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 4	10%	RACM	Good	100 square feet	F27002 8	4/5/2001

**SampleID** V2C313A-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 4	10%	RACM	Good	144 square feet	F27002 8	4/5/2001

**SampleID** V2C411-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 6	10%	RACM	Good	224 square feet	F27003 0	4/5/2001

**SampleID** V2D200-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 2	10%	RACM	Good	1105 square feet	F27002 6	4/5/2001

**SampleID** V2D324-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	2nd floor section 5	10%	RACM	Good	120 square feet	F27002 9	4/5/2001

**SampleID** V2FLSEC1-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 1	10%	RACM	Good	16355 square feet	F27002 5	4/5/2001

**SampleID** V2FLSEC2-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 2	10%	RACM	Good	1092 square feet	F27002 6	4/5/2001

**SampleID** V2FLSEC3-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 3	10%	RACM	Good	7090 square feet	F27002 7	4/5/2001

**SampleID** V2FLSEC4-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 4	10%	RACM	Good	5875 square feet	F27002 8	4/5/2001

**SampleID** V2FLSEC5-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 5	10%	RACM	Good	12425 square feet	F27002 9	4/5/2001

**SampleID** V2FLSEC6-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Floor Tile                      2nd floor section 6                      10%   RACM                      Good                      10745 square feet                      F27003  
0                      4/5/2001

**SampleID**                      *V2FLSEC7-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	2nd floor section 7	10%	RACM	Good	7635 square feet	F27003 1	4/5/2001

**Floor**    2nd Floor Crawlspace

**SampleID**                      *2CS-DI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
cork mastic on duct	Room 2CS.2nd floor cat walk section 7	3 %	RACM	Good	10 Surface Area	F27003 8	4/28/2001

**SampleID**                      *2CS-DI-002*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
cork mastic on duct	Room 2CS SECTION 7	3 %	RACM	Good	10 Surface Area	F27003 8	4/28/2001

**SampleID**                      *2CS-DI-003*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
cork mastic on duct	Room 2CS SECTION 7	3 %	RACM	Good	10 Surface Area	F27003 8	4/28/2001

**SampleID**                      *VCS-I10-TSI-2*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 1. Located B-D/ I 10	10%	RACM	Good	75 Linear Feet	F27003 2	3/14/2001

**SampleID** VCS-II2-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Run	2nd floor cat walk section 1	10%	RACM	Good	75 Linear Feet	F27003 2	3/14/2001

**SampleID** VCS-III9-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 3. B-D/ II 19	10%	RACM	Good	87 Linear Feet	F27003 4	3/14/2001

**SampleID** VCS-II20-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	2nd floor cat walk section 4. Location: B/II 19-II 20	10%	RACM	Good	4 Linear Feet	F27003 5	3/14/2001

**SampleID** VCS-II2-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 2. Location: B-D/ II 2	10%	RACM	Good	75 Linear Feet	F27003 3	3/14/2001

**SampleID** VCS-III2-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 4. Location B/ II 20	10%	RACM	Good	4 Linear Feet	F27003 5	3/14/2001

**SampleID** VCS-IV14-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Debris 2nd floor cat walk section 7. Located B/IV14 10% RACM Good 20 Linear Feet F27003 8 3/14/2001

**SampleID** VCS-IV19-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 7. Located B-D/IV 19	10%	RACM	Good	75 Linear Feet	F27003 8	3/14/2001

**SampleID** VCS-IV20-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	2nd floor cat walk section 7. Located B/ IV 20	10%	RACM	Good	25 Linear Feet	F27003 8	3/14/2001

**SampleID** VCS-IV2-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	2nd floor cat walk section 6. Location: B-C/ IV 2-IV 3	10%	RACM	Good	15 Linear Feet	F27003 7	3/14/2001

**SampleID** VCS-IV3-TSI-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	2nd floor cat walk section 6. Location: B-D/IV 3	10%	RACM	Good	75 Linear Feet	F27003 7	3/14/2001

**Floor** 3rd Floor

**SampleID** 3C115-SO-002

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room 3C115 SECTION 1	4 %	RACM	Significantly Damaged	50 Surface Area	F27003 9	4/3/2001

**Floor** 3rd Floor

*SampleID* 3C115-SO-002

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room 3C115 SECTION 1	4 %	RACM	Significantly Damaged	50	Surface Area	F27003 9	4/3/2001

**SampleID** 3C115-SO-003

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room 3C115 SECTION 1	4 %	RACM	Significantly Damaged	25 square feet	F27003 9	4/3/2001

**SampleID** 3C119-SO-001

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room, actual closet of 3C119 SECTION 1	4 %	RACM	Good	32 square feet	F27003 9	4/3/2001

**SampleID** V3C201-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	3rd floor section 2	10%	RACM	Good	302 square feet	F27004 0	4/5/2001

**SampleID** V3C209-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	3rd floor section 3	10%	RACM	Good	500 square feet	F27004 1	4/5/2001

**SampleID** V3D140-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	3rd floor section 2	10%	RACM	Good	320 square feet	F27004 0	4/5/2001

**SampleID** V3FLSECI-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Floor Tile	3rd floor section 1	10%	RACM	Good	14300 square feet	F27003 9	4/5/2001
------------	---------------------	-----	------	------	-------------------	-------------	----------

**SampleID**      *V3FLSEC2-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 2	10%	RACM	Good	14555 square feet	F27004 0	4/5/2001

**SampleID**      *V3FLSEC3-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 3	10%	RACM	Good	11285 square feet	F27004 1	4/5/2001

**SampleID**      *V3FLSEC4-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 4	10%	RACM	Good	8688 square feet	F27004 2	4/5/2001

**SampleID**      *V3FLSEC4-FT-RF*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 4	10%	RACM	Good	8820 square feet	F27004 2	4/5/2001

**SampleID**      *V3FLSEC5-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 5	10%	RACM	Good	3840 square feet	F27004 3	4/5/2001

**SampleID** V3FLSEC5-FT-RF

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 5	10%	RACM	Good	7488 square feet	F27004 3	4/5/2001

**SampleID** V3FLSEC6-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 6	10%	RACM	Good	6537 square feet	F27004 4	4/5/2001

**SampleID** V3FLSEC6-FT-RF

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 6	10%	RACM	Good	1130 square feet	F27004 4	4/5/2001

**SampleID** V3FLSEC7-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 7	10%	RACM	Good	3245 square feet	F27004 5	4/5/2001

**SampleID** V3FLSEC7-FT-RF

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	3rd floor section 7	10%	RACM	Good	2900 square feet	F27004 5	4/5/2001

**Floor** 3rd Floor Crawlspace

**SampleID** VCS-111-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
core chase	3rd floor cat walk section 1. Located I-11/B-D	10%	RACM	Good	85 Linear Feet	F27004 6	3/14/2001

**SampleID** VCS-115-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 3. Located C-D/I 15-I 14	10%	RACM	Good	4 Linear Feet	F27004 8	3/14/2001

**SampleID** VCS-115-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 1. Located B/I 5	10%	RACM	Good	2 Linear Feet	F27004 6	3/14/2001

**SampleID** VCS-116-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 1. Located B-C/I 6	10%	RACM	Good	4 Linear Feet	F27004 6	3/14/2001

**SampleID** VCS-113-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 3	10%	RACM	Good	1 Linear Feet	F27004 8	3/14/2001

**SampleID** VCS-118-TSI-3

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

4"-8" Pipe Run	3rd floor cat walk section 3. Located B-D/II 16-II 18	10%	RACM	Good	95 Linear Feet	F27004 8	3/14/2001
----------------	---	-----	------	------	----------------	-------------	-----------

**SampleID**      *VCS-III9-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 3. Located B-C/II 19-II 18	10%	RACM	Good	2 Linear Feet	F27004 8	3/14/2001

**SampleID**      *VCS-II2-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 2. Located B-D/II 2	10%	RACM	Good	75 Linear Feet	F27004 7	3/14/2001

**SampleID**      *VCS-II3-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	3rd floor cat walk section 2. Located C-D/II 3-II 2	10%	RACM	Good	12 Linear Feet	F27004 7	3/14/2001

**SampleID**      *VCS-II6-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Debris	3rd floor section 2. Located B-C/II 7- II 6	10%	RACM	Good	24 Linear Feet	F27004 7	3/14/2001

**SampleID**      *VCS-III10-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located C-B/III 10-III 11	10%	RACM	Good	2 Linear Feet	F27005 0	3/14/2001

**SampleID**      *VCS-III11-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located C-B/III 11- III 12	10%	RACM	Good	2 Linear Feet	F27005 0	3/14/2001

**SampleID**      *VCS-III12-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located C-B/III 12-III 13	10%	RACM	Good	2 Linear Feet	F27005 0	3/14/2001

**SampleID**      *VCS-III13-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located B/III 13- III 15	1-	RACM	Good	100 Linear Feet	F27005 0	3/14/2001

**SampleID**      *VCS-III9-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located B/III 9- III 10	10%	RACM	Good	4 Linear Feet	F27005 0	3/14/2001

**SampleID**      *VCS-IV10-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 6.	10%	RACM	Good	25 Linear Feet	F27005 1	3/14/2001

**SampleID**      *VCS-IV14-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

<4" Pipe Run	3rd floor cat walk section 7. Located C-B/IV 14- IV 15	10%	RACM	Good	2 Linear Feet	F27005 2	3/14/2001
--------------	--	-----	------	------	---------------	-------------	-----------

**SampleID** *VCS-IV17-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 7. Located IV 17/B-D	10%	RACM	Good	99 Linear Feet	F27005 2	3/14/2001

**SampleID** *VCS-IV20-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 7. Located B-C/IV 20	10%	RACM	Good	10 Linear Feet	F27005 2	3/14/2001

**SampleID** *VCS-IV2-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 5. Located B/ IV 2	10%	RACM	Good	4 Linear Feet	F27005 0	3/14/2001

**SampleID** *VCS-IV3-TSI-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	3rd floor cat walk section 6	10%	RACM	Good	75 Linear Feet	F27005 1	3/14/2001

**Floor** 4th Floor

**SampleID** *4D337-FT-007*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	Room 4D337 SECTION 6	2 %	Category 1 Nonfriable ACM	Good	340 square feet	F27005 8	3/20/2001

**Floor** 4th Floor

**SampleID** 4D337-FT-007

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	Room 4D337 SECTION 6	2 %	Category 1 Nonfriable ACM	Good	340 square feet	F27005 8	3/20/2001

**SampleID** 4D337-FT-007BT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	Room 4D337 SECTION 6	2 %	Category 1 Nonfriable ACM	Good	340 SF	F27005 8	4/3/2001

**SampleID** V4FLSEC1-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 1	10%	RACM	Good	2815 square feet	F27005 3	4/5/2001

**SampleID** V4FLSEC3-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 2	10%	RACM	Good	3736 square feet	F27005 4	4/5/2001

**SampleID** V4FLSEC4-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 4	10%	RACM	Good	6220 square feet	F27005 6	4/5/2001

**SampleID** V4FLSEC5-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 5	10%	RACM	Good	7064 square feet	F27005 7	4/5/2001

**SampleID** V4FLSEC6-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Floor Tile	4th floor section 6	10%	RACM	Good	6154 square feet	F27005 8	4/5/2001
------------	---------------------	-----	------	------	------------------	-------------	----------

**SampleID**      *V4FLSEC6-FT-RF*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 6	10%	RACM	Good	5208 square feet	F27005 8	4/5/2001

**SampleID**      *V4FLSEC7-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 7	10%	RACM	Good	4528 square feet	F27005 9	4/5/2001

**SampleID**      *V4FLSEC7-FT-RF*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	4th floor section 7	10%	RACM	Good	3168 square feet	F27005 9	4/5/2001

**Floor**    4th Floor Crawlspace

**SampleID**      *4CW-AC-01*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 4CW	5 %	RACM	Good	5 Linear Feet	F27006 0	4/28/2001

**SampleID**      *4CW-AC-02*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 4CW	5 %	RACM	Good	5 Linear Feet	F27005 3	4/28/2001

**SampleID** 4CW-AC-03

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room 4CW	5 %	RACM	Good	5 Linear Feet	F27006 0	4/28/2001

**SampleID** 4CW-TSI-01

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	Room 4CW SECTION 1	20%	RACM	Good	5 Linear Feet	F27006 0	4/28/2001

**SampleID** 4CW-TSI-02

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	Room 4CW SECTION 1	20%	RACM	Good	5 Linear Feet	F27006 0	4/28/2001

**SampleID** 4CW-TSI-03

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	Room 4CW SECTION 1	20%	RACM	Good	5 Linear Feet	F27006 0	4/28/2001

**SampleID** VCI10-TSI-4

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 1	10%	RACM	Good	20 Linear Feet	F27006 0	2/14/2002

**SampleID** VCI11-TSI-4

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

<4" Pipe Run	4th floor cat walk section 1	10%	RACM	Good	20 Linear Feet	F27006 0	2/14/2002
--------------	------------------------------	-----	------	------	----------------	-------------	-----------

**SampleID** *VCII8-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor section 3	10%	RACM	Good	70 Linear Feet	F27006 2	2/14/2001

**SampleID** *VCII2-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 2	10%	RACM	Good	70 Linear Feet	F27006 1	2/14/2002

**SampleID** *VCII3-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 2	10%	RACM	Good	22 Linear Feet	F27006 1	2/14/2002

**SampleID** *VCIII4-DI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Cork Insulation	4th floor cat walk section 4	10%	RACM	Good	Linear Feet	F27006 3	2/14/2002

**SampleID** *VCIV-20-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 7	10%	RACM	Good	3 Linear Feet	F27006 6	2/14/2002

**SampleID**      *VCIV-2-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 6	10%	RACM	Good	3 Linear Feet	F27006 5	2/14/2002

**SampleID**      *VCIV-3-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	4th floor cat walk section 6	10%	RACM	Good	25 Linear Feet	F27006 5	2/14/2002

**SampleID**      *VDI13-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	4th floor cat walk section 2	10%	RACM	Good	1 Linear Feet	F27006 1	2/14/2001

**SampleID**      *VDI14-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	4th floor cat walk section 2	10%	RACM	Good	1 Linear Feet	F27006 1	2/14/2001

**SampleID**      *VDI15-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	4th floor cat walk section 2	10%	RACM	Good	1 Linear Feet	F27006 1	2/14/2002

**SampleID**      *VDI13-TSI-4*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

<4" Pipe Run

4th floor cat walk section 2

10% RACM

Good

6 Linear Feet

F27006  
1

2/14/2002

<4" Pipe Run                      4th floor cat walk section 2                      10%   RACM                      Good                      6 Linear Feet                      F27006  
 1                      2/14/2002

**Floor**    Basement

*SampleID*                      OA418-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile Mastic	Mechanical Room OA418	8 %	Category 2 Nonfriable ACM	Good	300 Surface Area	FMOA4 18	1/22/1998

*SampleID*                      VOA400M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	Mechanical Room OA 400	10%	Category 1 Nonfriable ACM	Good	700 Surface Area	FMOA4 00	2/10/1998

**Floor**    First

*SampleID*                      1B204-AT-001B

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Acoustical Wall Tile	Room 1B204 section 3	2 %	Category 2 Nonfriable ACM	Good	200 square feet	F27000 6	4/4/2001

*SampleID*                      MR12-1

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 12	20%	RACM	Good	5 Linear Feet	F2700- 12	1/7/1998

*SampleID*                      MR12-2

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Pipe Insulation	Mechanical Room 12	15%	RACM	Good	5 Linear Feet	F2700-12	1/7/1998
-----------------	--------------------	-----	------	------	---------------	----------	----------

**SampleID** *MR12-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 12	30%	RACM	Good	5 Linear Feet	F2700-12	1/7/1998

**SampleID** *MR13-01*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Duct Insulation	Mechanical Room 13	33%	RACM	Good	100 Surface Area	F2700-13	1/22/1998

**SampleID** *V11M*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Elbow	Mechanical Room 11	20%	RACM	Good	10 Linear Feet	F2700-11	1/7/1990

**SampleID** *V12M*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 12	10%	RACM	Good	5 Linear Feet	F2700-12	1/7/1998

**SampleID** *V21AM*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	Mechanical Room 21A	10%	Category 1 Nonfriable ACM	Good	300 Surface Area	F2700-21	1/7/1998

**SampleID**      *VBRI*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Floor Tile	Boiler Room - First Floor	10%	Category 1 Nonfriable ACM	Good	750	Surface Area		1/7/1998

**SampleID**      *VMR1-1*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Floor Tile	Mechanical Room - 1st Floor	10%	Category 1 Nonfriable ACM	Good	100	Surface Area	F2700-1	1/7/1990

**SampleID**      *VMR1-2*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Flex Connector	Mechanical Room - 1st Floor	60%	Category 2 Nonfriable ACM	Good	5	Linear Feet	F2700-1	1/7/1998

**SampleID**      *VMR13*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 13	10%	RACM	Good	30	Linear Feet	F2700-13	1/22/1998

**SampleID**      *VMR1-3*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room - 1st Floor	10%	RACM	Good	10	Linear Feet	F2700-1	1/7/1998

**SampleID**      *VMR14*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount	Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 14	10%	RACM	Good	10	Linear Feet	F2700-14	1/7/1998

**Floor**    Fourth

**SampleID** B329

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Flex Connector	Mechanical Room 44	60%	Category 2 Nonfriable ACM	Good	10 Linear Feet	F2700-44	11/23/1981

**SampleID** B333

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Duct Insulation	Mechanical Room 43	10%	RACM	Good	1920 Surface Area	F2700-43	11/23/1981

**SampleID** B335

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Pipe Insulation	Mechanical Room 43	40%	RACM	Good	10 Linear Feet	F2700-43	11/23/1981

**SampleID** B337

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Patching Material	Mechanical Room 43	30%	RACM	Good	1920 Surface Area	F2700-43	11/23/1981

**SampleID** V43M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Electrical Wrap	Mechanical Room 43	10%	Category 2 Nonfriable ACM	Good	2 Linear Feet	F2700-43	1/7/1998

**SampleID** V44M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Tank Insulation	Mechanical Room 44	20%	RACM	Good	15 Surface Area	F2700-44	1/7/1998
-----------------	--------------------	-----	------	------	-----------------	----------	----------

*SampleID*      *V45M*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 44	20%	Category 2 Nonfriable ACM	Good	15 Linear Feet	F2700-44	1/7/1998

Tank Insulation	Mechanical Room 44	20%	RACM	Good	15 Surface Area	F2700-44	1/7/1998
-----------------	--------------------	-----	------	------	-----------------	----------	----------

**SampleID**      *V45M*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 44	20%	Category 2 Nonfriable ACM	Good	15 Linear Feet	F2700-44	1/7/1998

**Floor**      Mezzanine

**SampleID**      *1AB110-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 1	10%	RACM	Good	242 square feet	F270018	4/5/2001

**SampleID**      *1AB111-AT-008B*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Acoustical Wall Tile	Room 1 AB111 MEZZANINE SECTION 1	2 %	RACM	Good	1400 square feet	F270018	4/4/2001

**SampleID**      *1AB129-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 1	10%	RACM	Good	290 square feet	F270018	4/5/2001

**SampleID**      *1AB-212-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 3	10%	RACM	Good	1088 square feet	F270020	4/5/2001

**SampleID** VIAB111-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 1	10%	RACM	Good	448 square feet	F27001 8	4/5/2001

**SampleID** VIAB129-TSI-001

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Insulation	mezzanine section 2	10%	RACM	Good	8 square feet	F27001 9	4/5/2001

**SampleID** VIAB-312-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 4	10%	RACM	Good	608 square feet	F27002 1	4/5/2001

**SampleID** VIAB-324-TP

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	mezzanine section 5	10%	RACM	Good	7865 square feet	F27002 2	4/5/2001

**SampleID** VMEZSEC1-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	mezzanine section 1	10%	RACM	Good	12850 square feet	F27001 8	4/5/2001

**SampleID** VMEZSEC2-FT

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Floor Tile	mezzanine section 2	10%	RACM	Good	6921 square feet	F27001 9	4/5/2001
------------	---------------------	-----	------	------	------------------	-------------	----------

**SampleID** *VMEZSEC3-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	mezzanine section 3	10%	RACM	Good	1200 square feet	F27002 0	4/5/2001

**SampleID** *VMEZSEC4-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	mezzanine section 4	10%	RACM	Good	2728 square feet	F27002 1	4/5/2001

**SampleID** *VMEZSEC5-FT*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Floor Tile	mezzanine section 5	10%	RACM	Good	2664 square feet	F27002 2	4/5/2001

**Floor** O & A Level

**SampleID** *OA400-so-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room OA400. O & A LEVEL SECTION 6	30%	RACM	Good	562 SF	F27000 2	4/4/2001

**SampleID** *OA404-SO-002*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room OA404.O & A LEVEL SECTION 6	26%	RACM	Good	192 SF	F27000 2	4/4/2001

**SampleID**      *OA404-SO-003*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Sprayed-On Insulation	Room OA404.O & A LEVEL SECTION 6	25%	RACM	Good	960 SF	F27000 2	4/4/2001

**SampleID**      *OA504-FT-001M*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Mastic	Room OA504	2 %	Category 1 Nonfriable ACM	Good	3356 SF	F27000 3	4/4/2001

**SampleID**      *OA504-TSI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Room OA504.SECTION 7	66%	RACM	Removed	5 Linear Feet	F27000 3	4/4/2001

**SampleID**      *VOA400-TP-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	O & A section 6	10%	RACM	Good	880 square feet	F27000 2	4/28/2001

**SampleID**      *VOA400-TSI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A section 6	10%	RACM	Good	26 Linear Feet	F27000 2	4/28/2001

**SampleID**      *VOA404-CT-005*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
------------------	--------------------	------------------	----------------------	-----------	-------------	-----------	-------------

Transite Ceiling Tile      Room OA404.SECTION 6      10%    Category 1 Nonfriable ACM    Good      144 SF      F27000  
2      4/4/2001

**SampleID**      *VOA404-TP-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	O & A section 6	10%	RACM	Good	510 square feet	F27000 2	4/28/2001

**SampleID**      *VOA-500-TP*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite	O & A section 7	10%	RACM	Good	475 square feet	F27000 3	4/28/2001

**SampleID**      *VOABR-WG-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Window Glazing/Caulking	O & A section 5	10%	RACM	Good	160 Linear Feet	F27000 1	4/28/2001

**SampleID**      *VOACAF-TSI-001*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Insulation	Cafeteria compressor room VOACAF.O&A LEVEL SECTION 6	10%	RACM	Damaged	3 Linear Feet	F27000 2	4/6/2001

**SampleID**      *VOASW13-TSI-007*

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Stairway 13.O&A LEVEL SECTION 5	10%	RACM	Good	15 Linear Feet	F27000 1	4/6/2001

*SampleID* VOASW6-TSI-006

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	Stairway 6.O&A LEVEL SECTION 6	2 %	RACM	Good	6 Linear Feet	F27000 2	4/6/2001

**Floor** O & A Crawlspace

*SampleID* VCS-IV1-TSI-OA

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A cat walk section 5	10%	RACM	Good	100 Linear Feet	F27001	4/28/2001

*SampleID* VCS-IV2-TSI-OA

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A cat walk section 5	10%	RACM	Good	100 Linear Feet	F27001	4/28/2001

*SampleID* VCS-IV7-TSI-OA

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A cat walk section 6	10%	RACM	Good	50 square feet	F27002	4/28/2001

*SampleID* VCS-IV8-TSI-OA

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A cat walk section 6	10%	RACM	Good	1 Linear Feet	F27002	4/28/2001

*SampleID* VCS-IV9-TSI-OA

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
<4" Pipe Run	O & A cat walk section 6	10%	RACM	Good	1 Linear Feet	F27002	4/28/2001

**Floor** Second

**SampleID** V24M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 24	20%	Category 2 Nonfriable ACM	Good	15 Linear Feet	F2700-24	1/7/1998

**SampleID** V25M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 25	20%	Category 2 Nonfriable ACM	Good	15 Linear Feet	F2700-25	1/7/1998

**Floor** Third

**SampleID** MR35-01

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 35	20%	Category 2 Nonfriable ACM	Good	45 Linear Feet	F2700-35	1/7/1998

**SampleID** V34M

Asbestos Product	Location of Sample	Percent Asbestos	Category of Asbestos	Condition	Amount Unit	GraphicID	Sample Date
Transite Pipe	Mechanical Room 34	20%	Category 2 Nonfriable ACM	Good	15 Linear Feet	F2700-34	1/7/1998

## Summary of Negative Samples By Building

**BuildingNumber** 2700

**SampleID** IAB110-AT-010

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative		Type III acoustic wall tile throughout offices. Photo 79. *FY96-03 - See file for complete removal records. Removed VAT in Photo Lab,1B111,1B114, 1B136,2D109, 2D211,2D304,2C207, 2D305,3C&D121, 3C340, 3C205, 3C207, 3C109, 3C124,Conference Rm, Stariwell #10, Security room.. FY02-Removed duct insulation in Mech Rm #43 and 13. FY00- Removed transite walls in 4C129,4D116. Removed loose tiles in support of renovation thru- out the bldg. Removed loose ceiling tiles in closets.	4/4/2001

**SampleID** IAB111-AT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB111	Type I acoustic wall tile. Photo 76	4/4/2001

**SampleID** IAB111-AT-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	lab111	Adhesive behind type II tile tested 2.2% asbestos Photo#77	4/4/2001

**SampleID** IAB111-AT-009

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB111	On office doors, type III acoustic wall tile. Photo 78	4/4/2001

**SampleID** 1AB129-AT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB129	Type III acoustic wall board. Photo 73	4/4/2001

**SampleID** 1AB129-AT-005B

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	LAB 129	mastic backing type III acoustical wall tile Photo #73	4/4/2001

**SampleID** 1AB129-AT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB129	Type III acoustic wall tile. Photo 74	4/4/2001

**SampleID** 1AB138-AT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB138	Type IV acoustic wall tile. Photo 69	4/4/2001

**SampleID** 1AB138-AT-004B

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB138	Mastic on back of type IV acoustic wall tile. Photo 69	4/4/2001

**SampleID** 1AB138-CT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB138

Type I ceiling tile. Photo 70

4/4/2001

**SampleID** 1AB138-CT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB138

Type II ceiling tile. Photo 71

4/4/2001

**SampleID** 1AB212-AT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB212

Type I acoustical wall tile. Photo 66

4/4/2001

**SampleID** 1AB312-CT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB312

Type I ceiling tile. Photo 65

4/4/2001

**SampleID** 1AB318-AT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB318

Type III - Acoustic wall tile. Photo 59

4/4/2001

**SampleID** 1AB318-AT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IAB318

Type II - acoustial wall tileabove ceiling. Photo 60

4/4/2001

**SampleID** 1AB318-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room lab 3 and 8	Type I ceiling tile. Photo 61	4/6/2001

**SampleID** 1AB318-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB318	Type II ceiling tile. Photo 62	4/4/2001

**SampleID** 1AB318-RP-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1 AB318	White 1st floor bulding managers office.Photo# 135	4/28/2001

**SampleID** 1AB324-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB324	Type IV ceiling tile. Photo 63	4/4/2001

**SampleID** 1AB324-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room IAB324	Type I ceiling tile. Photo 64	4/4/2001

**SampleID** 1B106-FT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 1B106 12 X 12 Beige Red Stripe floor tile Photo#27 3/20/2001

**SampleID** 1B113-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B113 12 X 12 white red speckled floor tile Photo#28 3/20/2001

**SampleID** 1B113-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B113 12 X 12 Beige Floor Tile Photo#29 3/20/2001

**SampleID** 1B121-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative room 1B121 12 X 12 white speckled floor tile Photo#30 3/20/2001

**SampleID** 1B136-FT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B136 12 X 12 Charcoal Floor Tile Photo#31 3/20/2001

**SampleID** 1B204-AT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B204 Type II acoustic wall tile mini-auditorium - MER. Photo 37. Backing adhesive contains asbestos. 4/4/2001

**SampleID** 1B204-AT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B204	Type IV acoustic wall tile. Photo 39. Mini auditorium - MER	4/4/2001

**SampleID** 1B204-AT-002B

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B204	Mastic from type IV acoustial tile. Mini auditorium - MER. Photo 40	4/4/2001

**SampleID** 1B204-AT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B204	Type I acoustical wall tile. Photo 41	4/4/2001

**SampleID** 1B314-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B314	Type I ceiling tile	4/6/2001

**SampleID** 1B314-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B314	Type 4 ceiling tile. Photo 116	4/6/2001

**SampleID** 1B325-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B325 Type I ceiling tile. Photo 114 4/6/2001

**SampleID** 1B415-AT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B415 Type VI acoustical wall tile. Photo 42. Front wall library. 4/4/2001

**SampleID** 1B415-AT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1B415 Type I acoustic wall tile. Photo 43. Library next to door. 4/4/2001

**SampleID** 1CS-BC-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 1st floor cs stairwell#3 1st Floor Crawlspace Stairwell #3. Photo #134 4/28/2001

**SampleID** 1CS-BC-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1 CS Brown coat 1st floor stairwell #3 4/28/2001

**SampleID** 1CS-BC-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 1 CS 1st floor stairwell #7. Photo# 134 4/28/2001

**SampleID** 2700-02

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	basement boiler room, duct in ceiling		10/19/1999

**SampleID** 2CS-BC-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2CS	Brown coat column I-2 crawlspace	4/28/2001

**SampleID** 2CS-BC-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2CS	Column IV-12 brown coat	4/28/2001

**SampleID** 2CS-BC-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2CS. Located 2nd floor cat walk section 6.D-C/IV 11-IV 12	Column IV-12 brown coat	4/28/2001

**SampleID** 2CS-BC-009

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2CS.2nd floor cat walk section 7	Column IV-20 brown coat	4/28/2001

**SampleID** 2CS-SO-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 2nd floor cat walk section 1. Located C-D/I2-I1 2nd floor cat walk section 1. Located C-D/ I2- I1 3/14/2001

*SampleID* 2CS-SO-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 2nd floor cat walk section 1. Located C-DI 2- I 1 2nd floor cat walk section 1. Located C-D/ I 2- I 1 3/14/2001

*SampleID* 2CS-SO-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 2nd floor cat walk section 1. Located C-D/ I 2- I 1 2nd floor cat walk section 1. Located C-D/ I 2- I 1 3/14/2001

*SampleID* 2CS-SO-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2CS Brown coat column I-2 crawlspace 4/28/2001

*SampleID* 2CS-SO-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2CS Brown column I-2 crawlspace 4/28/2001

*SampleID* 2D108A-AT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D108A Type IV acoustic wall tile, photo 45 4/4/2001

**SampleID** 2D120-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D120	Type I ceiling tile, photo 107	4/6/2001

**SampleID** 2D120-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D120	Type II ceiling tile, photo 108	4/6/2001

**SampleID** 2D120-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D120	Type IV ceiling, photo 109	4/6/2001

**SampleID** 2D126-FT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D126	12 X 12 white speckled floor tile Photo# 15	3/20/2001

**SampleID** 2D140-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D140	12X12 white speckled floor tile, photo 16	3/20/2001

**SampleID** 2D141-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D141 Type II ceiling tile. Photo 103 4/6/2001

*SampleID* 2D200-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D200 12X12 beige dark red stripe floor tile, photo 17 3/20/2001

*SampleID* 2D306-FT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D306 12X12 white speckled floor tile, photo 20 3/20/2001

*SampleID* 2D307-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D307 12X12 beige red stripe floor tile, photo 18 3/20/2001

*SampleID* 2D308-FT-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D308 12X12 beige floor tile, photo 22 3/20/2001

*SampleID* 2D312-FT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 2D312 12X12 grey speckled floor tile, photo 19 3/20/2001

**SampleID** 2D406-CT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D406	Type II ceiling tile, photo 111	4/6/2001

**SampleID** 2D505-FT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 2D505	12x12 pink floor tile, photo 21	3/20/2001

**SampleID** 2DEL-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room elevator lobby, 2DEL	Type II ceiling tile, photo 110	4/6/2001

**SampleID** 2DEL-CT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room, elevator lobby, 2DEL	Type I ceiling tile, photo 112	4/6/2001

**SampleID** 2DEL-CT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room, elevator lobby, 2DEL	Type II ceiling tile, photo 113	4/6/2001

**SampleID** 3C124-FT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3C124 12X12 beige red stripe floor tile. Photo 9 3/20/2001

**SampleID** 3C203-AT-013

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3C203 Type V acoustic wall tile. Photo 58 4/4/2001

**SampleID** 3C215-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3C215 12X12 grey floor tile. Photo 11 3/20/2001

**SampleID** 3C318-FT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3C318 12X12 beige red stripe floor tile. Photo 14 3/20/2001

**SampleID** 3CS-BC-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3CS. 3rd floor cat walk section 5. Brown coat Brown column 4-2CS 4/28/2001

**SampleID** 3CS-BC-001B

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative 3rd floor cat walk column 4-2CS 3rd floor cat walk section 5 white coat plaster sample taken no asbestos photo #128 4/28/2001

*SampleID* 3CS-BC-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3CS.3rd floor cat walk section 4.Located B-C/III3-III4	Brown coat column 3-4CS	4/28/2001

*SampleID* 3CS-BC-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3CS	Brown coat column #2CS	4/28/2001

*SampleID* 3D141-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D141	Type I ceiling tile. Photo 102	4/6/2001

*SampleID* 3D141-CT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D141	Type VII, Photo 105	4/6/2001

*SampleID* 3D141-CT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D141	Type VII ceiling tile. Photo 105	4/6/2001

*SampleID* 3D141-CT-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D141 Type VII ceiling tile. Photo 105 4/6/2001

*SampleID* 3D141-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D141 12X12 brown speckled floor tile. 3/20/2001

*SampleID* 3D304-AT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D304 Type V acoustical wall tile. Photo 49 4/4/2001

*SampleID* 3D304-AT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D304 Type V acoustic wall tile. Photo 50 4/4/2001

*SampleID* 3D304-AT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D304 Type V acoustic wall tile. Photo 51 4/4/2001

*SampleID* 3D307-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D307 Type I ceiling tile. Photo 100 4/6/2001

**SampleID** 3D307-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D307	Type II ceiling tile. Photo 101	4/6/2001

**SampleID** 3D312-AT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D312	Type VII acoustical wall tile. Photo 46	4/4/2001

**SampleID** 3D312-AT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D312.Interior wall of lab-East	Type VII acoustical wall tile. Photo 47	4/4/2001

**SampleID** 3D312-AT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D312	Type VII acoustical wall tile. Photo 48	4/4/2001

**SampleID** 3D324-AT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D324	Type V acoustic wall tile. Photo 52	4/4/2001

**SampleID** 3D324-AT-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D324 Type V acoustic wall tile. Photo 53 4/4/2001

*SampleID* 3D324-AT-009

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D324 Type V acoustic wall tile. Photo 54 4/4/2001

*SampleID* 3D324-AT-010

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D324 Type I acoustic wall tile. Photo 55 4/4/2001

*SampleID* 3D324-AT-011

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D324 Type I acoustic wall tile. Photo 56 4/4/2001

*SampleID* 3D324-AT-012

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D324 Type I acoustic wall tile. Photo 57 4/4/2001

*SampleID* 3D325-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 3D325 12X12 beige red stripe floor tile. Photo 12 3/20/2001

**SampleID** 3D337-FT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D337	12X12 peach floor tile. Photo 13	3/20/2001

**SampleID** 3D414-CT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3D414	Type IV ceiling tile. Photo 104	4/6/2001

**SampleID** 3DEL-CT-009

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 3DEL, elevator lobby	Type II ceiling tile. Photo 106	4/6/2001

**SampleID** 4C115-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 4C115	12X12 white speckled floor tile. Photo 2	3/20/2001

**SampleID** 4C138-FT-008

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 4C138	12X12 pink floor tile. Photo # 8	3/20/2001

**SampleID** 4D105-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D105 12X12 beige red stripe floor tile. Photo # 3 3/20/2001

**SampleID** 4D211-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D211 Type I ceiling tile. Photo #95 4/6/2001

**SampleID** 4D211-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D211 Type II ceiling tile. Photo 96 4/6/2001

**SampleID** 4D309-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D309 12X12 beige red stripe floor tile. Photo # 4 3/20/2001

**SampleID** 4D314-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D314 Type IV ceiling tile. Phot 93 4/6/2001

**SampleID** 4D314-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4D314 Type I ceiling tile. Photo 94 4/6/2001

**SampleID** 4D314-FT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 4D314	12X12 royal blue floor tile. Photo # 5	3/20/2001

**SampleID** 4D337-FT-007BM

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	4D337	under rug in Pat Pitt's office, Floor Mastic.Yellow, homogenous.	4/3/2001

**SampleID** 4D503-FT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 4D503	12X12 white speckled floor tile. Photo # 6	3/20/2001

**SampleID** 4DEL-CT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room elevator lobby.	Type I ceiling tile. Photo 97.	4/6/2001

**SampleID** 4DEL-CT-006

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room elevator lobby	Section 1 - elevator lobby, type 2 ceiling tile. Photo 98	4/6/2001

**SampleID** 4DEL-CT-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room 4DEL

Section 1, elevator lobby, type IV ceiling tile. Photo #4

4/6/2001

**SampleID** B314

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 45 - acoustical tiles on doors

Another sample (B317) of this material was also found not to contain asbestos.

11/20/1981

**SampleID** B315

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 45 - pipe elbow insulation

Another sample taken of the pipe elbow insulation (B316) was also found not to contain asbestos.

11/20/1981

**SampleID** B316

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 45 - pipe elbow insulation

Another sample taken of the pipe elbow insulation (B315) was also found not to contain asbestos.

11/20/1981

**SampleID** B317

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 45 - acoustical tiles on doors

Another sample (B314) of this material was also found not to contain asbestos.

11/20/1981

**SampleID** B319

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 45 - Pipe insulation 3" line plastic coated

11/20/1981

**SampleID** B322

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 45 - Flex connection for duct.		11/20/1981

**SampleID** B324

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 45 - duct insulation foil wrapped.		11/20/1981

**SampleID** B327

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical room 44 - wall panel section (masonite)	Another sample (B328) collected was also found not to contain asbestos.	11/23/1981

**SampleID** B328

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 44 - wall panel section (masonite)	Another sample (B327) collected was also found not to contain asbestos.	11/23/1981

**SampleID** B331

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 43 - acoustical tile on doors		11/23/1981

**SampleID** BR01

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room OA Floor - Tanks (3 adjacent) Two additional samples of the tanks were also found not to contain asbestos (BR02, BR03). 1/7/1998

*SampleID* BR02

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room OA Floor - Tanks (3 adjacent) Two additional samples of the tanks were also found not to contain asbestos (BR01, BR03). 1/7/1998

*SampleID* BR03

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room OA Floor - Tanks (3 adjacent) Two additional samples of the tanks were also found not to contain asbestos (BR01, BR02). 1/7/1998

*SampleID* BR04

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room - OA Floor, Boiler head / Flue Two additional samples of the boiler head were found not to contain asbestos (BR05, BR06). 1/7/1998

*SampleID* BR05

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room - OA Floor, Boiler head / Flue Two additional samples of the boiler head were found not to contain asbestos (BR04, BR06). 1/7/1998

*SampleID* BR06

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Boiler Room - OA Floor, Boiler head / Flue Two additional samples of the boiler head were found not to contain asbestos (BR04, BR05). 1/7/1998

*SampleID* BR07

<b>Result</b>	<b>Location of Sample</b>	<b>Miscellaneous Notes</b>	<b>Sample Date</b>
Negative	Boiler Room - First floor, water tank with flag	Two additional samples collected of the tank also did not contain asbestos (BR08, BR09).	1/7/1998

*SampleID* BR08

<b>Result</b>	<b>Location of Sample</b>	<b>Miscellaneous Notes</b>	<b>Sample Date</b>
Negative	Boiler Room - First Floor, water tank with flag.	Two additional samples collected of the tank also did not contain asbestos (BR07, BR09).	1/7/1998

*SampleID* BR09

<b>Result</b>	<b>Location of Sample</b>	<b>Miscellaneous Notes</b>	<b>Sample Date</b>
Negative	Boiler Room - First Floor, water tank with flag	Two additional samples collected of the tank also did not contain asbestos (BR07, BR08).	1/7/1998

*SampleID* BR10

<b>Result</b>	<b>Location of Sample</b>	<b>Miscellaneous Notes</b>	<b>Sample Date</b>
Negative	Boiler Room OA Floor - condensate tank	Two additional samples of the condensate tank were found not to contain asbestos (BR11, BR12).	1/7/1998

*SampleID* BR11

<b>Result</b>	<b>Location of Sample</b>	<b>Miscellaneous Notes</b>	<b>Sample Date</b>
Negative	Boiler Room OA Floor - condensate tank	Two additional samples of the condensate tank were found not to contain asbestos (BR10, BR12).	1/7/1998

**SampleID** BR12

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Boiler Room OA Floor - condensate tank	Two additional samples of the condensate tank were found not to contain asbestos (BR10, BR11).	1/7/1998

**SampleID** BR13

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Boiler Room - First Floor Pipe Joints		1/7/1998

**SampleID** BR14

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Boiler Room - OA Floor, pipe joint insulation	An additional sample of pipe joint insulation was also found not to contain asbestos (BR15).	1/7/1998

**SampleID** BR15

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Boiler Room - OA Floor, pipe joint insulation	An additional sample of pipe joint insulation was also found not to contain asbestos (BR14).	1/7/1998

**SampleID** MIAB138-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1AB138	12X12 Beige floor tile. Photo 24	3/20/2001

**SampleID** M1AB324-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1AB324	12X12 Blue floor tile.	3/20/2001

**SampleID** M1AB411-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room M1AB411	12X12 Beige floor tile. Photo 26	3/20/2001

**SampleID** M1B129-FT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room 1B129	12X12 Black/white floor tile. Photo 23	3/20/2001

**SampleID** MEZAUDCS-HP-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room MEZAUDCS	Beige hanger patch auditorium crawlspace	4/28/2001

**SampleID** MEZAUDCS-HP-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room MEZAUDCS	Beige hanger patch auditorium crawlspace	4/28/2001

**SampleID** MEZAUDCS-TSI-08

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room MEZAUDCS Beige TSI elbow 4/28/2001

**SampleID** MEZAUDCS-TSI-09

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room MEZAUDCS Beige TSI elbows 4/28/2001

**SampleID** MEZAUDCS-TSI-10

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room MEZAUDCS Beige TSI elbows 4/28/2001

**SampleID** MEZAUDCS-TSI-11

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room MEZAUDCS Beige TSI elbows 4/28/2001

**SampleID** MEZAUDCS-TSI-12

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room MEZAUDCS Beige TSI elbows 4/28/2001

**SampleID** MEZAUD-SO-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room: Mezzanine auditorium wall material Auditorium black/white stage right. Spray on on wall of auditorium 4/28/2001

**SampleID** MEZAUD-SO-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room MEZAUD	Auditorium black/white stage right	4/28/2001

**SampleID** MEZAUD-SO-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room MEZAUD	Auditorium white/black stage left	4/28/2001

**SampleID** MEZAUD-TSI-007

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room MEZAUDCS	Beige TSI elbows	4/28/2001

**SampleID** MR13-02

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 13	Two additional samples of the duct insulation were collected. MR13-01 was positive, and MR13-03 was negative.	1/22/1998

**SampleID** MR13-03

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 13	Two additional samples of the duct insulation were collected. MR13-01 was positive, and MR13-02 was negative.	1/22/1998

**SampleID** MR21-01

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 21A - spray-on ceiling material	Two additional samples (MR21-02, MR21-03) of the sprayed-on material were found not to contain asbestos.	1/7/1998

**SampleID** MR21-02

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 21A - spray-on ceiling material	Two additional samples (MR21-01, MR21-03) of the sprayed-on material were found not to contain asbestos.	1/7/1998

**SampleID** MR21-03

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 21A - spray-on ceiling material	Two additional samples (MR21-01, MR21-02) of the sprayed-on material were found not to contain asbestos.	1/7/1998

**SampleID** MR33-01

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 31 - wall tile mastic	No suspect asbestos containing materials were observed in the mechanical room.	1/7/1998

**SampleID** MR41-01

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 41 - Flex Connector	No other suspect asbestos containing materials were observed in the mechanical room.	1/7/1998

**SampleID** OA400-AT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA400	Type IV - acoustic wall tile. Photo 88	4/4/2001

**SampleID** OA400-AT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA400	OA 404 - 1st office west wall Type II - acoustica west tile <1% asbestos based on homogenous type II positive samples these material shall be handled as asbestos containing.	4/4/2001

**SampleID** OA404-CT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA404	Type I ceiling tile by phone closet. Photo 85	4/4/2001

**SampleID** OA404-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA404	Type 5 ceiling tile in plenum. Photo 86	4/4/2001

**SampleID** OA404-FT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA404	12X12Beige floor tile. Photo 32	3/20/2001

**SampleID** OA418-1

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room OA418 - floor tile mastic	Two additional samples of the mastic were collected. OA418-02 was positive, and OA418-03 was negative. There were no other suspected asbestos containing materials in the mechanical room.	1/22/1998

**SampleID** OA418-3

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room OA418	Two additional samples of the mastic were collected. OA418-02 was positive, and OA418-01 was negative. There were no other suspected asbestos containing materials in the mechanical room.	1/22/1998

**SampleID** OA500-FT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA500	12X12 Beige Floor tile. Photo 33. Mastic beneath 12X12 beige contains 2.2% asbestos.	3/20/2001

**SampleID** OA500-FT-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA500	12X12 white floor tile. Photo 34. Mastic beneath 12X12 white floor tile contains 2.2% asbestos.	3/20/2001

**SampleID** OA500-FT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA500	12X12 beige red stripe. Photo 35. Mastic beneath 12X12 beige red stripe contains 2.2% asbestos.	3/20/2001

**SampleID** OA500-FT-005

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA500	12X12 gray red stripe. Photo 36. Mastic beneath 12X12 grey red stripe floor tile contains 2.2% asbestos.	3/20/2001

**SampleID** OA504-CT-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Room OA504	Type I ceiling tile. Photo 80	4/4/2001

**SampleID** OACAF-DI-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Cafeteria dry-food storage area	Duct installation on exhaust unit for cafeteria grill. Photo 119	4/6/2001

**SampleID** OACAF-SO-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Cafeteria	Spray-on fireproofing throughout cafeteria. Photo 120	4/6/2001

**SampleID** OACAF-SO-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Cafeteria	Spray-on fire-proofing throughout cafeteria. Photo 121	4/6/2001

**SampleID** OA-CS-BC-001

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room OA Brown coat OA-stariwell #7 4/28/2001

*SampleID* OA-CS-BC-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room OA Brown coat OA-stairwell #6 4/28/2001

*SampleID* OA-CS-BC-003

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room OA Brown coat OA-stairwell #13 4/28/2001

*SampleID* OAEL-CT-002

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room OAEL Type II ceiling tile. Photo 84 4/4/2001

*SampleID* V1B114-CT-004

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Room IB114 VISUAL No sample collected. Visual identification determined new ceiling tile. 4/6/2001

*SampleID* V21M

Result	Location of Sample	Miscellaneous Notes	Sample Date
--------	--------------------	---------------------	-------------

Negative Mechanical Room 21 No suspect asbestos containing materials are present in the mechanical room. 1/7/1998

**SampleID** V22M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 22	No suspect asbestos containing materials are present in the mechanical room.	1/7/1998

**SampleID** V23M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 23	No suspect asbestos containing materials are present in the mechanical room.	1/7/1998

**SampleID** V31M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 31	One suspect material, wall tile mastic, was sampled in mechanical room 33 and found not to contain asbestos (sample MR33-01). No other suspect ACM were observed in the mechanical room,	1/7/1998

**SampleID** V32M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 32	No suspect asbestos containing material was found present in the mechanical room.	1/7/1998

**SampleID** V33M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 33 - Flex Connector	No other asbestos containing materials were observed in the mechanical room.	1/7/1998

**SampleID** V42M

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 42	No suspect asbestos containing materials were observed in the mechanical room.	1/7/1998

**SampleID** VMR15

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room 15	No suspect asbestos containing materials were observed in the mechanical room.	1/28/1998

**SampleID** VMRM405

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room - Mezzanine above 405	No suspect asbestos containing materials were observed in the mechanical room.	1/22/1998

**SampleID** VOA417

Result	Location of Sample	Miscellaneous Notes	Sample Date
Negative	Mechanical Room OA417	No suspect asbestos containing materials were present in the mechanical room.	1/7/1998